



Manufacturer's Declaration

Per STANDATA Variance, February 14, 2007
September 21, 2007

This Declaration is to confirm that the NOSHOK products listed herein meet the requirements of a single seal device as defined in ANSI/ISA 12.27.01-2003.

The sensors of these products have been tested to CSA Standard C22.2, No. 30-M1986, CI 4.10.6 and ANSI S82.03 clause 18.2.2 under FM J.I.3009489.

NOSHOK has initiated a CSA International project for "Single Seal" compliance as defined by ANSI/ISA 12.27.01-2003.

Single seal compliance eliminates the requirement for additional sealing per Canadian Electrical Code C22.1-06, rules 18-092, 18-108, 18-158, J18-108 and J18-158.

A completion date of October 01, 2007 is expected.

NOSHOK Products

621 Series Pressure Transmitters
623 Series Pressure Transmitters
625 Series Pressure Transmitters

NOSHOK, Inc.

Jeff N. Scott
President

Robert Manjura
Quality Manager

CORPORATE HEADQUARTERS
1010 WEST BAGLEY ROAD
BEREA, OHIO 44017
440-243-0888 • Fax 440-243-3472
E-Mail: noshok@noshok.com • Web: www.noshok.com

MDANSIISA092507